

Wheatland Rural Electric Association  
Post Office Box 1209  
Wheatland, Wyoming 82201

PSC No. 2  
2nd Revised Sheet No. 24  
Cancels 1st Revised Sheet No. 24

**ENERGY DEVELOPMENT**

Rate Code: ED

**APPLICABLE:**

Service to Energy Development, within the service area of the Association, subject to the rules and regulations of the Association and of Regulatory Authorities.

**AVAILABLE:**

Energy Development

**TYPE OF SERVICE:**

Single-phase or Three-phase, 60 hertz, at available secondary voltage.

**MONTHLY RATE:**

Facilities Charge	\$1.50 per Month per installed KVA capacity
Plus	
Demand Charge:	\$5.78 per kW of Demand
Plus	
Energy Charge:	\$0.0819 per kWh

**MONTHLY MINIMUM BILL:**

The monthly minimum charge is the higher of the following:

- A. Single phase \$37.20; or
- B. Three phase \$67.20; or
- C. \$1.50 per kVA of Association installed capacity

**DETERMINATION OF DEMAND:**

The demand shall be the maximum demand established by the consumer for any period of fifteen (15) consecutive minutes during the month for which the bill is rendered, as indicated or recorded by a demand meter.

**TERMS OF PAYMENT:**

Payment for all bills for electric service must be postmarked ten (10) days following the date of bill mailing. Bills not paid by the next following bill date may be assessed a one and one-half percent (1.5%) late payment charge. This charge will be on the delinquent balance brought forward on the subsequent month's bill.

Payments received shall satisfy the oldest portion of the billing first.

**FILED**  
PUBLIC SERVICE COMMISSION  
OF WYOMING

NOV 20 2013

Date Issued: November 20, 2013

Date Effective: January 1, 2014

Approved By: 

Title: General Manager

Wheatland Rural Electric Association  
Post Office Box 1209  
Wheatland, Wyoming 82201

PSC No. 2  
2nd Revised Sheet No. 25  
Cancels 1st Revised Sheet No. 25

---

ENERGY DEVELOPMENT

Rate Code: ED

---

PHASE CONVERTERS:

The maximum motor size for use with a single-phase to three-phase converter is 30 hp. Converters must meet, as a minimum, the requirements of Section 10 "Recommended Practices for individual Consumers" of the IEEE Standard 519-1998 "IEEE Recommended Practices and Requirements for Harmonic Control in Electrical Power Systems". Appropriate starting control devices for motors must be installed. Any proposed motor/converter application will require a study at the Consumer's expense to determine whether more stringent size and performance limitations would be required on an application-specific basis.

If the consumer use of the motor/converter has an abnormal effect on system voltage or current flow (as determined by the Association), the consumer shall be required to install such equipment as to correct the problem within 90 days after notification; or the Association may either install such equipment to correct the problem at the expense of the consumer, or disconnect such consumer in order to protect the quality of Electric Service to other existing consumers and the Association's electrical system.

The Association may install a meter that has the capability to record any harmonic distortions placed on the Association's electrical system. Such meter shall be at the expense of the Consumer desiring to utilize a phase converter.

POWER FACTOR ADJUSTMENT:

Demand charges will be adjusted to correct for average power factors lower than ninety-five percent (95%) if and when Association deems necessary. Such adjustments shall be made by increasing the measured demand one percent (1%) for each one percent (1%) by which the average power factor is less than ninety-five percent (95%) leading or lagging.

FILED  
PUBLIC SERVICE COMMISSION  
OF WYOMING

NOV 20 2013

---

Date Issued: November 20, 2013

Date Effective: January 1, 2014

Approved By: 

Title: General Manager